

TOWN OF MAYNARD BOARD OF HEALTH

TOWN OF MAYNARD
MEETING NOTICE POSTED IN ACCORDANCE WITH THE PROVISIONS OF MGL 30A §18-25

Agenda – August 18, 2015 – 6:30 p.m. - Town Hall (*195 Main Street*)

Scheduled Hearing

- 1 Ethelyn Circle – Local Upgrade/Variance request for septic system repair.
 - 310 CMR 15.405(1)(a) Variance request to allow a sewage disposal leaching area to be 2.0 feet from the property line instead of the required 10 feet.
 - 310 CMR 15.405(1)(b) Variance request to allow a sewage disposal leaching area to be 14.1 feet from a cellar wall instead of the required 20 feet.
 - 310 CMR 15.405(1)(h) Variance request to allow a sewage disposal leaching area to be 3 feet from high groundwater elevation instead of the required 4 feet.

New Business

- Any item not anticipated at time of posting

Old Business

- Miscellaneous

General Business

- Health Agent update- Housing/Nuisance
- Mosquito Control
- Landfill Monitoring
- BOH meeting dates
- Any item not anticipated at time of posting

Minutes

- Minutes of the June 23, 2015 meeting
- Minutes of the July 28, 2015 meeting

THIS AGENDA IS SUBJECT TO CHANGE
CHAIRPERSON: RON CASSIDY
POSTED BY: KELLY PAWLUCZONEK
DATE: August 12, 2015

